

## **Proposal Request**

**Project:**

*Rifle Fire Protection District  
Fire Station #3  
416 Last Chance Drive  
Rifle, CO 81650*

**Owner:**

*Rifle Fire Protection District  
1850 Railroad Ave.  
Rifle, CO 81650*

**From Architect:**

*Johnson Carter Architects, PC.  
136 East Third Street; suite B  
Rifle, CO 81650*

**Proposal Request Number:** *12R*

**Date of Issuance:** *9-22-09*

**Contract For:**

*Design Services*

**Contract Dated:**

*Nov. 20, 2008*

**Architect's Project Number:**

*0808F*

**To Contractor:**

*Kuersten Construction, LLC.  
0013 Powerline Road  
Rifle, CO 81650*

---

Please submit an itemized proposal for changes in the Contract Sum and Contract Time for proposed modifications to the Contract Documents described herein. Within ( ) days, the Contractor must submit this proposal or notify the Architect, in writing, of the date on which proposal submission is anticipated.

**THIS IS NOT A CHANGE ORDER, A CONSTRUCTION CHANGE DIRECTIVE OR A DIRECTION TO PROCEED WITH THE WORK DESCRIBED I THE PROPOSED MODIFICATIONS.**

**Description:**

*Provide a detailed cost breakdown (labor, material, mark-up...) for the following revision:*

*Provide 2 – 2” conduit runs from the location of the communication antenna and through the CMU wall along grid 3. At the north side of the CMU wall on grid 3 continue 1 – 2” conduit line to the ceiling space above the IT Room. The communication antenna is to be located at the exterior face of the CMU/stucco finish at the north – east corner of the Apparatus Bay (locate antenna on east wall at this location). Conduit run to be routed around the exposed ceiling in the Day Room/Kitchen Area.*

**Attachments:**

*None*

---

**Request by the Architect:**

---

Richard Carter (Owner/Architect)