

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number 7
Date: 8/12/2009

RFI DESCRIPTION: (Fully describe the question or type of information requested.)

Can we get the following information in regards to the sprinkler system: Where to roughin for the control box, pipe size for supply to sprinkler system, where it ties into water system, backflow preventer if required, and brand of control box.

REFERENCES: (List specific documents when seeking the information requested.)

SPECIFICATIONS:

DRAWINGS:

OTHER:

SENDER'S RECOMMENDATION:

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)

Control box is to be located in the Mechanical/Electrical Room (#127). Pull off 1" irrigation line before the domestic backflow preventer. Provide a backflow preventer on 1" line (either a reduced pressure backflow preventer or vacuum breaker backflow preventer - dependent on city standards)