

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number: 10
Date: 8/13/2009

RFI DESCRIPTION: (Fully describe the question or type of information requested.)

Refer to shop drawing 203

See Mk. 203A

Note b203

1. What is the weld required for the FB $\frac{1}{2}$ x $6\frac{1}{2}$ to the cut taper of the W21 x 44 over the length of 27' 6 $\frac{1}{2}$ "?

Refer to shop drawing 300

See Mk. 300A

Note a300

2. The bar grating will require being cut out to allow the pass through of the FB $\frac{5}{8}$ x 2 and #2 clevis. Is this correct?

SENDER'S RECOMMENDATION:

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)

1. SEE SHOP DWG. 203 SECTION "A" FOR REQ'D WELD. (ALSO DET. 7/34.1)
2. CUT BAR GRATING AS REQ'D.

LANDON ANDERSON
CADD ENGINEERING
8-17-09