

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number 12
Date: 8/13/2009

RFI DESCRIPTION: (Fully describe the question or type of information requested.)

At the West end of the sloping roof where the tapered beams are, there is a W24x62 (202D - see approval E-4). This beam appears on S2.1 to extend all the way across the door to the closet in room 125 to the corner of the walls. It was approved as stopping at the edge of the cap plate as is shown in detail 2/S4.1. Does this beam need to cantilever all the way to the corner of the wall or does it stop at the column as it was detailed / approved? Please verify.

REFERENCES: (List specific documents when seeking the information requested.)

SPECIFICATIONS:

DRAWINGS:

OTHER:

S2.1

SENDER'S RECOMMENDATION:

THE W24x62 BEAM IS ACCEPTABLE AS DETAILED / APPROVED.
ROOF TRUSSES SHALL BE COORDINATED TO UTILIZE THE BEARING
WALL THAT IS EAST AND PARALLEL TO THE W24.

LANEY JOHNSON
ODD ENGINEERING
8-17-09

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)