

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number: 19
Date: 8/19/2009

RFI DESCRIPTION: (Fully describe the question or type of information requested.)

Sheet E2-3 shows power going to a collector pump, please clarify what and where this pump is located. I believe that the collector pump was deleted and replaced with a detention facility on sheet C3.0. Please Clarify

REFERENCES: (List specific documents when seeking the information requested.)

SPECIFICATIONS:

DRAWINGS:

OTHER:

SENDER'S RECOMMENDATION:

Delete power running to pump and add power for heat trace on detention facility (note 5 on C3.0)

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)

There are no longer any explicit reasons for power supply for a pump on the civil sheets. I concur, power supply for a pump is not required according to RMC - RMC 8/21/09