

## ***Request for Information***

**Contractor:** Kuersten Construction  
Address: 0013 Powerline Road  
City, State: Rifle Colorado  
Zip: 81650  
Phone: 970-625-8210

**A/E:** Johnson & Carter Architects  
Address: 136 East 3rd Street Suite B  
City, State: Rifle, Colorado 81650  
Zip: 81650  
Phone: 970-625-0580

**Project:** RFPD Fire Station #3  
RFI Number: 1  
Date: 7/10/2009

**RFI DESCRIPTION:** (Fully describe the question or type of information requested.)  
Can we wet set anchor bolts for shear walls rather than drilling and using epoxy.

**REFERENCES:** (List specific documents when seeking the information requested.)

*SPECIFICATIONS:*

*DRAWINGS:*

*OTHER:*

**SENDER'S RECOMMENDATION:**

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

*It is acceptable to cast in place anchor bolts for shear walls in lieu of post installed anchors. Use 7/8" dia. anchors with 15" embedment. Anchors shall be headed studs or threaded rods with a heavy hex nut at the base and standard washer. Nut shall be tack welded to rod.*