

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number: 20
Date: 8/19/2009

RFI DESCRIPTION: (Fully describe the question or type of information requested.)

We need to continue with the back fill of the foundation walls, once the SOG is in place we think shoring of the apparatus bay walls along grid line D will be necessary to help keep the tall concrete wall from moving. Please provide a bracing detail if movement is a concern. Please advise.

REFERENCES: (List specific documents when seeking the information requested.)

SPECIFICATIONS:

DRAWINGS:

OTHER:

SENDER'S RECOMMENDATION:

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)

THE FOUNDATION WALL @ GRID D IS DESIGNED AS A CAPTILEVER
RETAINING WALL. ONCE THE SLAB ON GRADE IS IN PLACE THE
WALL CAN BE BACKFILLED WITHOUT ADDITIONAL SHORING.

LONDON ANDERSON
0000 ENGINEERING
8-20-09