

## **Request for Information**

**Contractor:** Kuersten Construction  
Address: 0013 Powerline Road  
City, State: Rifle Colorado  
Zip: 81650  
Phone: 970-625-8210

**A/E:** Johnson & Carter Architects  
Address: 136 East 3rd Street Suite B  
City, State: Rifle, Colorado 81650  
Zip: 81650  
Phone: 970-625-0580

**Project:** RFPD Fire Station #3  
RFI Number: 23  
Date: 8/21/2009

**RFI DESCRIPTION:** (Fully describe the question or type of information requested.)

On sheet C-4 there is a note saying, "Proposed 15' Easement for Fire Hydrant", where does it go?

**REFERENCES:** (List specific documents when seeking the information requested.)

*SPECIFICATIONS:*

*DRAWINGS:*

*OTHER:*

**SENDER'S RECOMMENDATION:**

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

The hydrant was deleted late in the permit approval process. No 15' easement for a fire hydrant is required.  
RMC - 8/24/09