

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number: 30
Date: 9/1/2009


RFI DESCRIPTION: (Fully describe the question or type of information requested.)

Is Hilti HY-150 Max sufficient for all of our drill and epoxy situations? Threaded Rod Tension=7275 lbs. Threaded Rod Shear=8275 lbs. #5 Rebar Ultimate Bond Strength=25060 lbs, and #5 Rebar Yield Strength=18600 pounds.

SENDER'S RECOMMENDATION:

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)

HILTI HY-150 MAX IS ACCEPTABLE FOR ALL DRILL & EPOXY APPLICATIONS.


0000 ENGINEERING
9.2.09