

## Request for Information

**Contractor:** Kuersten Construction  
Address: 0013 Powerline Road  
City, State: Rifle Colorado  
Zip: 81650  
Phone: 970-625-8210

**A/E:** Johnson & Carter Architects  
Address: 136 East 3rd Street Suite B  
City, State: Rifle, Colorado 81650  
Zip: 81650  
Phone: 970-625-0580

**Project:** RFPD Fire Station #3  
RFI Number: 35  
Date: 9/4/2009

**RFI DESCRIPTION:** (Fully describe the question or type of information requested.)

Reference RFI 13 Questions 2 & 7

Please verify elevations given in responses are correct. When compared back to structural shops & contract drawings columns and beams appear to have elevation issues. Please Advise

**REFERENCES:** (List specific documents when seeking the information requested.)

*SPECIFICATIONS:*

*DRAWINGS:*

*OTHER:*

**SENDER'S RECOMMENDATION:**

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

TO S EL 109'0" IS CORRECT FOR ALL BEAMS. BEAM 200B WAS ORIGINALLY  
DESIGNED TO KING POST DOWN TO HEADER BEAM 200B. THE ELEVATION OF  
200B WAS SUBSEQUENTLY DETERMINED TO BE 109'0 PER ARCH'L.  
BEAM 200B CAN BE CONNECTED TO BEAM 200B WITH SHEAR PLATE  
DTL. 3/59.1.