



## Request for Information

**Contractor:** Kuersten Construction  
Address: 0013 Powerline Road  
City, State: Rifle Colorado  
Zip: 81650  
Phone: 970-625-8210

**A/E:** Johnson & Carter Architects  
Address: 136 East 3rd Street Suite B  
City, State: Rifle, Colorado 81650  
Zip: 81650  
Phone: 970-625-0580

**Project:** RFPD Fire Station #3  
RFI Number: 37  
Date: 9/15/2009

**RFI DESCRIPTION:** (Fully describe the question or type of information requested.)

Reference: RFI #9 Response

See: powder actuated fasteners

Note: Are powder actuated fasteners acceptable on the roof as well.

**REFERENCES:** (List specific documents when seeking the information requested.)

**SPECIFICATIONS:**

**DRAWINGS:**

**OTHER:**

**SENDER'S RECOMMENDATION:**

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

METAL ROOF DECKING MAY BE ATTACHED USING 0.145" Ø POWDER ACTUATED FASTENERS. SEE O.T.L. 9/54.1 FOR EDGE FASTENING REQUIREMENTS. USE 3/4" PATTERN AS SHOWN ON NUCCA DRAWING NO. 01 FOR END LAPS AND INTERMEDIATE SUPPORTS. SIDE LAPS SHALL BE SCREWED W/(2) #10 SCREWS PER SPAN.

LANSON ANDERSON  
OPDD ENGINEERING

9-21-09