

## **Request for Information**

**Contractor:** Kuersten Construction  
Address: 0013 Powerline Road  
City, State: Rifle Colorado  
Zip: 81650  
Phone: 970-625-8210

**A/E:** Johnson & Carter Architects  
Address: 136 East 3rd Street Suite B  
City, State: Rifle, Colorado 81650  
Zip: 81650  
Phone: 970-625-0580

**Project:** RFPD Fire Station #3  
RFI Number: 39  
Date: 9/28/2009

**RFI DESCRIPTION:** (Fully describe the question or type of information requested.)

Reference PR #6, the following information is being requested:

1. The PR requests to include added power for equipment in the new room, but does not identify the new electrical loads. What are the electrical requirements of the new equipment?  
It appears there is an addition of a server, security equipment and IT rack.
2. Do we need to add a smoke detector in this room?

**REFERENCES:** (List specific documents when seeking the information requested.)

*SPECIFICATIONS:*

*DRAWINGS:*

*OTHER:*

**SENDER'S RECOMMENDATION:**

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

See attached sketch for reconfiguration. The circuit #8 from PP1 will be used to power equipment in the new server room. The copier may or may not be located in the room as shown. There is a lack of space as it is configured for the copier. A single data outlet will be located in the server room. Since this is a sprinklered building, if a sprinkler head is installed in this room then a smoke detector will not be necessary. If the Fire department decides that they want a fire suppression system in the room then a smoke detector will not be necessary. If they chose to not add a fire suppression system nor put a sprinkler head in the room then a smoke

