

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number: 4
Date: 7/15/2009

RFI DESCRIPTION: (Fully describe the question or type of information requested.)
At Grid line 12 between A and D please provide a detail showing the elevation of the brick ledge.

REFERENCES: (List specific documents when seeking the information requested.)

SPECIFICATIONS:

DRAWINGS:

OTHER:

SENDER'S RECOMMENDATION:

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)

Detail 5/S4.0 shows the brick ledge to be below finished grade. This is not a critical structural issue. The ledge should work with final grades such that the brick is below grade per arch'l. Verify with Arch. Set ledge so that coursing begins below grade (minimal level) and courses out at top of brick elevation as indicated on architectural drawings (response from JCA)