

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number: 52
Date: 10/16/2009

RFI DESCRIPTION: (Fully describe the question or type of information requested.)

Reference the architectural grating in front of the apparatus bay doors. Does the grating need to be banded?

REFERENCES: (List specific documents when seeking the information requested.)

SPECIFICATIONS:

DRAWINGS:

OTHER:

SENDER'S RECOMMENDATION:

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)

No banding required