

## ***Request for Information***

**Contractor:** Kuersten Construction  
Address: 0013 Powerline Road  
City, State: Rifle Colorado  
Zip: 81650  
Phone: 970-625-8210

**A/E:** Johnson & Carter Architects  
Address: 136 East 3rd Street Suite B  
City, State: Rifle, Colorado 81650  
Zip: 81650  
Phone: 970-625-0580

**Project:** RFPD Fire Station #3  
RFI Number: 5  
Date: 7/21/2009

**RFI DESCRIPTION:** (Fully describe the question or type of information requested.)

Where does the drain board system on details 3 and 4 on sheet R2 start and stop, in reference to the plans.

**REFERENCES:** (List specific documents when seeking the information requested.)

*SPECIFICATIONS:*

*DRAWINGS:*

*OTHER:*

**SENDER'S RECOMMENDATION:**

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

The drain board system indicated on sheet R2 will essentially follow the the location of the perimeter drain pipe as indicated by HP Geotech. The drain board system will be located along wall at grid 01 from D - G, wall at grid D from 01 - 02, wall on grid 2 from A - D, wall on grid A from 02 - 04 and wall on grid A from 05 - 07.