

Request for Information

Contractor: Kuersten Construction
Address: 0013 Powerline Road
City, State: Rifle Colorado
Zip: 81650
Phone: 970-625-8210

A/E: Johnson & Carter Architects
Address: 136 East 3rd Street Suite B
City, State: Rifle, Colorado 81650
Zip: 81650
Phone: 970-625-0580

Project: RFPD Fire Station #3
RFI Number: 6
Date: 7/21/2009

RFI DESCRIPTION: (Fully describe the question or type of information requested.)
What is the length and the dimensioned location of the trench drain in the apparatus bay.

REFERENCES: (List specific documents when seeking the information requested.)

SPECIFICATIONS:

DRAWINGS:

OTHER:

SENDER'S RECOMMENDATION:

RECEIVER'S REPLY: (Provide answer to RFI, including cost and/or schedule considerations.)

Refer to Architectural drawings for location and size of the cast in place trench drain.
Trench drain is to be 91'-0" long. Refer to attached drawing for location of trench drain

& 7/A3.3 for wardrobe
details
- refer to 05/A6.2
zzer and annunciator
electrical drawings

Apparatus Bay
Rm 100

19'-6"
masonry to center of drain

101'-0"

