

## ***Request for Information***

**Contractor:** Kuersten Construction  
Address: 0013 Powerline Road  
City, State: Rifle Colorado  
Zip: 81650  
Phone: 970-625-8210

**A/E:** Johnson & Carter Architects  
Address: 136 East 3rd Street Suite B  
City, State: Rifle, Colorado 81650  
Zip: 81650  
Phone: 970-625-0580

**Project:** RFPD Fire Station #3  
RFI Number: 8  
Date: 8/12/2009

**RFI DESCRIPTION:** (Fully describe the question or type of information requested.)  
How should the slab in the Apparatus Bay be sloped?

**REFERENCES:** (List specific documents when seeking the information requested.)

*SPECIFICATIONS:*

*DRAWINGS:*

*OTHER:*

**SENDER'S RECOMMENDATION:**

From the garage doors to trench drain @ 1%. From Grid D to East Wall of Weight Room flat at 100'.  
From East wall of Weight room to trench drain sloped. The slope is determined by the math from garage doors to trench drain.

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

**Sender's recommendation is correct - refer to attached drawing for visual clarification**

