

## Request for Information

**Contractor:** Kuersten Construction  
Address: 0013 Powerline Road  
City, State: Rifle Colorado  
Zip: 81650  
Phone: 970-625-8210

**A/E:** Johnson & Carter Architects  
Address: 136 East 3rd Street Suite B  
City, State: Rifle, Colorado 81650  
Zip: 81650  
Phone: 970-625-0580

**Project:** RFPD Fire Station #3  
RFI Number: 50  
Date: 10/16/2009

**RFI DESCRIPTION:** (Fully describe the question or type of information requested.)

Architectural drawings 16/A6.4 vs. structural drawings S1.2 are in conflict of the specified engineered truss sheathing. Is it acceptable to use 5/8" plywood for truss sheathing using the fastening system indicated on S1.2?

**REFERENCES:** (List specific documents when seeking the information requested.)

**SPECIFICATIONS:**

**DRAWINGS:**

**OTHER:**

**SENDER'S RECOMMENDATION:**

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

IT IS ACCEPTABLE TO USE 23/32" C-D PLYWOOD PER DWG. S1.2.  
FASTENING SHALL BE PER ROOF DIAPHRAGM SCHEDULE.

LANDON ANDERTON  
0000 ENGINEERING

10-21-09